

AD-A270 602



DEPARTMENT OF THE AIR FORCE  
HEADQUARTERS AIR FORCE CIVIL ENGINEERING SUPPORT AGENCY  
TYNDALL AIR FORCE BASE FL 32403-6001

①

REPLY TO  
ATTN OF

HQ AFCEA/EN  
139 Barnes Drive, Suite 1  
Tyndall AFB FL 32403-5319

13 JUL 1993

SUBJECT: Engineering Technical Letter (ETL) 93-2: Dormitory Criteria for Humid Areas

TO: Distribution List

1. Purpose. This letter provides the design criteria to ensure control of humidity inside dormitories in humid areas. Areas not covered by this ETL remain in accordance with existing guidance.

2. Application. This ETL applies to the design of new or renovated dormitories at Air Force bases in humid areas as described below that are not 35 percent designed. Ultimate recipients of this ETL are MAJCOMs, bases, and Air Force design and construction agents responsible for facilities in humid areas.

3. Specific Requirements.

3.1. Introduction. Existing criteria for Air Force dormitory facilities do not control interior space humidity successfully when applied in humid areas. For the purpose of this ETL, humid areas are defined as having over 3000 hours of 67°F or higher wet bulb temperature in combination with an outside design condition of 50 percent relative humidity or higher, or over 1500 hours of 73°F or higher wet bulb temperature in combination with an outside design condition of 50 percent relative humidity or higher, based on 2.5 percent dry bulb and 5 percent wet bulb temperatures. The high ambient moisture and temperature common in high humidity areas reverse vapor flow through building components and increase the latent cooling load on HVAC equipment when compared to the design conditions for most other CONUS locations. These unique conditions require design criteria different than that of the conventional wisdom used in other areas.

3.2. Building Envelope. The building envelope design shall:

3.2.1. Place the least permeable material or vapor retarder on the exterior side of the building insulation and place more permeable materials inside the building insulation.

SD  
ELECTE  
OCT 14 1993  
A D

This document has been approved  
for public release and sale; its  
distribution is unlimited.

93-23849



93 10 8 008



*Providing Professional and Technical Services Worldwide*

3.2.2. Provide interior surfaces of exterior walls that will allow water vapor within the wall to escape into the conditioned space. Vinyl wallcoverings, multiple coats of oil-based paint, and other vapor-resistant materials will not be used as interior finishes of exterior walls.

3.2.3. For double wythe walls, place the vapor retarder on the exterior side of the inner wythe.

3.2.4. Analyze the vapor flow through the building insulation systems, wall sections, and roof/ceiling sections. The variety of roof/ceiling systems available to the designer and the concepts for attic ventilation prevent definitive requirements from being established; however, roof/ceiling/insulation systems will reflect the following principles:

3.2.4.1. Place the vapor retarder exterior to the insulation. In some cases, the roof membrane may serve as the vapor retarder.

3.2.4.2. Ventilate spaces created exterior to the roof/ceiling vapor retarder.

3.2.4.3. Prohibit outside air entry into spaces created interior of the thermal envelope formed by the roof/ceiling insulation. Ventilation of such spaces, if required, must use air from conditioned spaces.

3.2.5. Seal all openings: around doors and windows, lintels, utility penetrations, seams in vapor retarders and air barriers, intersections of walls and roofs, etc. Provide details of vapor barrier treatments for these conditions.

3.2.6. Ensure that moisture transfer from ventilated attics into the building is minimized the same as walls.

3.2.7. Provide details to minimize thermal bridging, especially at door and window frames and the intersections of walls and roofs.

3.2.8. Provide sufficient floor-to-floor height, vertical distribution space, and mechanical equipment space to accommodate a ducted all-air HVAC system.

### 3.3. Mechanical Systems.

3.3.1. New Facilities. New facilities shall employ central station air handling units (AHUs) that supply conditioned air to variable air volume (VAV) terminal units with integral heating coils. VAV terminal units shall be the air throttling type consisting of a pressure-independent air valve which is modulated in response to space temperature. Fan-powered terminal units shall not be used. Fan coil unit air conditioning equipment shall not be used.

DTIC QUALITY INSPECTED 2

1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	
101	
102	
103	
104	
105	
106	
107	
108	
109	
110	
111	
112	
113	
114	
115	
116	
117	
118	
119	
120	
121	
122	
123	
124	
125	
126	
127	
128	
129	
130	
131	
132	
133	
134	
135	
136	
137	
138	
139	
140	
141	
142	
143	
144	
145	
146	
147	
148	
149	
150	
151	
152	
153	
154	
155	
156	
157	
158	
159	
160	
161	
162	
163	
164	
165	
166	
167	
168	
169	
170	
171	
172	
173	
174	
175	
176	
177	
178	
179	
180	
181	
182	
183	
184	
185	
186	
187	
188	
189	
190	
191	
192	
193	
194	
195	
196	
197	
198	
199	
200	
201	
202	
203	
204	
205	
206	
207	
208	
209	
210	
211	
212	
213	
214	
215	
216	
217	
218	
219	
220	
221	
222	
223	
224	
225	
226	
227	
228	
229	
230	
231	
232	
233	
234	
235	
236	
237	
238	
239	
240	
241	
242	
243	
244	
245	
246	
247	
248	
249	
250	
251	
252	
253	
254	
255	
256	
257	
258	
259	
260	
261	
262	
263	
264	
265	
266	
267	
268	
269	
270	
271	
272	
273	
274	
275	
276	
277	
278	
279	
280	
281	
282	
283	
284	
285	
286	
287	
288	
289	
290	
291	
292	
293	
294	
295	
296	
297	
298	
299	
300	
301	
302	
303	
304	
305	
306	
307	
308	
309	
310	
311	
312	
313	
314	
315	
316	
317	
318	
319	
320	
321	
322	
323	
324	
325	
326	
327	
328	
329	
330	
331	
332	
333	
334	
335	
336	
337	
338	
339	
340	
341	
342	
343	
344	
345	
346	
347	
348	
349	
350	
351	
352	
353	
354	
355	
356	
357	
358	
359	
360	
361	
362	
363	
364	
365	
366	
367	
368	
369	
370	
371	
372	
373	
374	
375	
376	
377	
378	
379	
380	
381	
382	
383	
384	
385	
386	
387	
388	
389	
390	
391	
392	
393	
394	
395	
396	
397	
398	
399	
400	
401	
402	
403	
404	
405	
406	
407	
408	
409	
410	
411	
412	
413	
414	
415	
416	
417	
418	
419	
420	
421	
422	
423	
424	
425	
426	
427	
428	
429	
430	
431	
432	
433	
434	
435	
436	
437	
438	
439	
440	
441	
442	
443	
444	
445	
446	
447	
448	
449	
450	
451	
452	
453	
454	
455	
456	
457	
458	
459	
460	
461	
462	
463	
464	
465	
466	
467	
468	
469	
470	
471	
472	
473	
474	
475	
476	
477	
478	
479	
480	
481	
482	
483	
484	
485	
486	
487	
488	
489	
490	
491	
492	
493	
494	
495	
496	
497	
498	
499	
500	
501	
502	
503	
504	
505	
506	
507	
508	
509	
510	
511	
512	
513	
514	
515	
516	
517	
518	
519	
520	
521	
522	
523	
524	
525	
526	
527	
528	
529	
530	
531	
532	
533	
534	
535	
536	
537	
538	
539	
540	
541	
542	
543	
544	
545	
546	
547	
548	
549	
550	
551	
552	
553	
554	
555	
556	
557	
558	
559	
560	
561	
562	
563	
564	
565	
566	
567	
568	
569	
570	
571	
572	
573	
574	
575	
576	
577	
578	
579	
580	
581	
582	
583	
584	
585	
586	
587	
588	
589	
590	
591	
592	
593	
594	
595	
596	
597	
598	
599	
600	
601	
602	
603	
604	
605	
606	
607	
608	
609	
610	
611	
612	
613	
614	
615	
616	
617	
618	
619	
620	
621	
622	
623	
624	
625	
626	
627	
628	
629	
630	
631	
632	
633	
634	
635	
636	
637	
638	
639	
640	
641	
642	
643	
644	
645	
646	
647	
648	
649	
650	
651	
652	
653	
654	
655	
656	
657	
658	
659	
660	
661	
662	
663	
664	
665	
666	
667	
668	
669	
670	
671	
672	
673	
674	
675	
676	
677	
678	
679	
680	
681	
682	
683	
684	
685	
686	
687	
688	
689	
690	
691	
692	
693	
694	
695	
696	
697	
698	
699	
700	
701	
702	
703	
704	
705	
706	
707	
708	
709	
710	
711	
712	
713	
714	
715	
716	
717	
718	
719	
720	
721	
722	
723	
724	
725	
726	
727	
728	
729	
730	
731	
732	
733	
734	
735	
736	
737	
738	
739	
740	
741	
742	
743	
744	
745	
746	
747	
748	
749	
750	
751	
752	
753	
754	
755	
756	
757	
758	
759	
760	
761	
762	
763	
764	
765	
766	
767	
768	
769	
770	

3.3.2. Existing Facilities. Existing facilities to be renovated shall incorporate VAV systems as described for new facilities in 3.3.1. above.

3.3.3. General Requirements.

3.3.3.1. Terminal Heating. Terminal heating shall be applied locally at the conditioned space. The terminal heating design shall utilize recovered heat in accordance with ASHRAE STD 90.1 for reheat and other simultaneous heating and cooling.

3.3.3.2. Reheat. Air-conditioning systems in less humid geographical areas normally distribute cooling air at 55°F to 60°F. In humid areas, lower cooling coil discharge air temperatures are required to provide necessary latent cooling capacity and offset moisture gains through the building envelope. This lower coil discharge temperature may require the use of a reheat coil downstream of the AHU to bring supply air temperatures in line with normal practice and ensure that the exterior surfaces of the ductwork remain above the dew point temperature of the building ambient air. The application of this reheat coil, if used, will be in accordance with ASHRAE STD 90.1 for reheat and other simultaneous heating and cooling. Access sections shall be provided between the fan and the reheat coil.

3.3.3.3. Heat Recovery. Condenser heat recovery will be utilized for terminal heating coils in the VAV units and the reheat coil. Use of condenser heat recovery for reducing the domestic hot water load will also be considered.

3.3.3.4. Preheat. Some humid area applications may require tempering or preheating the minimum outside air to prevent freezing and/or nuisance trips of the freeze protection devices. The designer shall determine the winter design mixed-air temperature resulting from mixing the minimum outside air quantity at the winter outside air design temperature and the return air at its expected condition. If necessary, provide the central AHU with a preheat-only coil located in the outside air duct to temper the winter supply air for the VAV system. Provide preheat control to maintain a constant mixed-air temperature.

3.3.3.5. Heating. Provide an appropriately-sized heating source to meet heating requirements and back up the sources of recovered heat.

3.3.3.6. Controls. Provide control strategies as specified in Army Technical Manual TM 5-815-3, Heating, Ventilating, and Air-Conditioning (HVAC) Control Systems, except as indicated below.

3.3.3.6.1. Space heating for VAV systems shall use VAV terminal units with integral heating coils. Control shall be proportional type by the variable air terminal controller in response to a room thermostat. The heating coil control valve shall modulate open after the primary air supply to the space is at minimum setting. Deadband type thermostats will not be used in Air Force construction.

3.3.3.6.2. Cooling/dehumidification shall be accomplished by cooling coils in the AHUs. Control shall be constant leaving air temperature. Determine the leaving air set point by an engineering analysis. Leaving air set point shall not exceed 55°F.

3.3.3.6.3. Economizer cycle will not be used in Air Force construction.

3.3.3.7. Ventilation Air. Minimum outside air quantities shall comply with ASHRAE STD 62 or as required for building pressurization, whichever is larger. Positive pressure shall be maintained to reduce infiltration. Ventilation air shall be 110 percent to 120 percent of exhaust air for all spaces with direct mechanical exhaust.

3.3.3.8. Exhaust System. A central ducted exhaust system shall be used in lieu of individual exhaust fans for each space. The exhaust system shall run continuously and be interlocked with the building supply air system. The exhaust duct for each space shall have a manual volume damper accessible from the space for proper balancing.

3.3.3.9. Air Path. Return air shall be ducted. Closet and storage spaces shall have louvered doors, and return air shall be drawn through these spaces. In the event there are no closets or storage spaces, the return air shall be drawn through the utility area between the living space and the bathroom.

3.3.3.10. Equipment Selection.

3.3.3.10.1. Cooling coil fin density shall be indicated on equipment schedules at 8 fins/inch maximum to ensure a cleanable coil and competitive bidding. Face velocities shall not exceed 550 ft/min to preclude moisture carryover.

3.3.3.10.2. The minimum number of cooling coil rows shall be specified in the equipment schedules. The number of rows shall be based on a comparison of data from at least three manufacturers and ensure that latent cooling loads can be met or exceeded.

3.3.3.10.3. Cooling coil entering and leaving air conditions shall be specified (wet and dry bulb temperatures) at the maximum airflow rate.


3.3.3.11. System Layout.

3.3.3.11.1. To the maximum extent possible, chilled water piping shall not be concealed in walls or ceilings of occupied spaces.

3.3.3.11.2. Insulate chilled water piping with cellular glass type insulation with an exterior vapor barrier.

3.3.3.11.3. Access panels, sufficiently sized, shall be located for maintenance of VAV boxes, dampers, controls, and associated components.

4. Commissioning. Dormitory HVAC systems will be commissioned to verify and document actual performance of the HVAC systems and evaluate conformity with the design intent. Air Force ETL 90-9, Commissioning of Heating, Ventilating, and Air Conditioning (HVAC) Systems, or Corps of Engineers Guide Specification, CECS 15995, Commissioning of HVAC Systems, will be used to develop the contract requirements for commissioning.

  
DENNIS M. FIRMAN, PE  
Director of Systems Engineering

2 Atch

1. Distribution List
2. ETL Index

# ENGINEERING TECHNICAL LETTERS (ETL)

## SECTION A - CURRENT ETLs

ETL Number	Title	Date Issued
82-2	Energy Efficient Equipment	10 Nov 82
83-1	Design of Control Systems for HVAC	16 Feb 83
	Change No. 1 to ETL 83-1, U.S. Air	
	Force Standardized Heating, Ventilating	
	& Air Conditioning (HVAC) Control Systems	22 Jul 87
83-3	Interior Wiring Systems, AFM 88-15	
	Para 7-3	2 Mar 83
83-4	EMCS Data Transmission Media (DTM)	
	Considerations	3 Apr 83
83-7	Plumbing, AFM 88-8, Chapter 4	30 Aug 83
83-8	Use of Air-to-Air Unitary Heat Pumps	15 Sep 83
83-9	Insulation	14 Nov 83
84-2	Computer Energy Analysis	27 Mar 84
	Change 1 Ref: HQ USAF/LEEEU Msg	
	031600Z MAY 84 1 Jun 84	
84-7	MCP Energy Conservation Investment	
	Program (ECIP)	13 Jun 84
84-10	Air Force Building Construction and	
	the Use of Termiticides	1 Aug 84
86-2	Energy Management and Control Systems	
	(EMCS)	5 Feb 86
86-4	Paints and Protective Coatings	12 May 86
86-5	Fuels Use Criteria for Air Force	
	Construction	22 May 86
86-8	Aqueous Film Forming Foam Waste	
	Discharge Retention and Disposal	4 Jun 86
86-9	Lodging Facility Design Guide	4 Jun 86
86-10	Antiterrorism Planning and	
	Design Guidance	13 Jun 86
86-14	Solar Applications	15 Oct 86
86-16	Direct Digital Control Heating	
	Ventilation and Air Conditioning Systems	9 Dec 86
87-1	Lead Ban Requirements of Drinking Water	15 Jan 87
87-2	Volatile Organic Compounds	4 Mar 87
87-4	Energy Budget Figures (EBFs) for	
	Facilities in the Military Construction	
	Program	13 Mar 87
87-5	Utility Meters in New and Renovated	
	Facilities	13 Jul 87
87-9	Prewiring	21 Oct 87
88-2	Photovoltaic Applications	21 Jan 88
88-3	Design Standards for Critical Facilities	15 Jun 88
88-4	Reliability & Maintainability (R&M)	
	Design Checklist	24 Jun 88
88-6	Heat Distribution Systems Outside of	
	Buildings	1 Aug 88

# ENGINEERING TECHNICAL LETTERS (ETL)

## SECTION A - CURRENT ETLs

ETL Number	Title	Date Issued
88-9	Radon Reduction in New Facility Construction	7 Oct 88
88-10	Prewired Workstations Guide Specification	29 Dec 88
89-2	Standard Guidelines for Submission of Facility Operating and Maintenance Manuals	23 May 89
89-3	Facility Fire Protection Criteria for Electronic Equipment Installations	9 Jun 89
89-4	Systems Furniture Guide Specification	6 Jul 89
89-6	Power Conditioning and Continuation Interfacing Equipment (PCCIE) in the Military Construction Program (MCP)	7 Sep 89
89-7	Design of Air Force Courtrooms	29 Sep 89
90-1	Built-Up Roof (BUR) Repair/Replacement Guide Specification	23 Jan 90
90-2	General Policy for Prewired Workstations and Systems Furniture	26 Jan 90
90-3	TEMPEST Protection for Facilities Change 1 Ref: HQ USAF/LEEDE Ltr dated 20 April 90, Same Subject	20 Apr 90
90-4	1990 Energy Prices and Discount Factors for Life-Cycle Cost Analysis	24 May 90
90-5	Fuel and Lube Oil Bulk Storage Capacity for Emergency Generators	26 Jul 90
90-6	Electrical System Grounding, Static Grounding and Lightning Protection	3 Oct 90
90-7	Air Force Interior Design Policy	12 Oct 90
90-8	Guide Specifications for Ethylene Propylene Diene Monomer (EPDM) Roofing	17 Oct 90
90-9	Fire Protection Engineering Criteria for Aircraft Maintenance, Servicing, and Storage Facilities	2 Nov 90
90-10	Commissioning of Heating, Ventilating, and Air Conditioning (HVAC) Systems Guide Specification	17 Oct 90
91-1	Fire Protection Engineering Criteria Testing Halon Fire Suppression Systems	2 Jan 91
91-2	High Altitude Electromagnetic Pulse (HEMP) Hardening in Facilities	4 Mar 91
91-3	Water Supply for Fire Protection	14 Jun 91
91-4	Site Selection Criteria for Fire Protection Training Areas	14 Jun 91
91-5	Fire Protection Engineering Criteria - Emergency Lighting and Marking of Exits	18 Jun 91
91-6	Cathodic Protection	3 Jul 91

Atch 2  
(2 of 3)

# ENGINEERING TECHNICAL LETTERS (ETL)

## SECTION A - CURRENT ETLs

ETL Number	Title	Date Issued
91-7	Chlorofluorocarbon (CFC) Limitation in Heating, Ventilating and Air-Conditioning (HVAC) Systems	21 Aug 91
93-1	Construction Signs	11 Mar 93
93-2	Dormitory Criteria for Humid Areas	13 Jul 93

## SECTION B - OBSOLETE ETLs

No.	Date	Status
82-1	10 Nov 82	Superseded by ETL 83-10, 86-1, 87-4
82-3	10 Nov 82	Superseded by ETL 83-5, 84-2
82-4	10 Nov 82	Superseded by ETL 84-7
82-5	10 Nov 82	Superseded by ETL 84-1, 86-13, 86-14
82-6	30 Dec 82	Cancelled
82-7	30 Nov 82	Cancelled
83-2	16 Feb 83	Superseded by ETL 84-3
83-5	5 May 83	Superseded by ETL 84-2
83-6	24 May 83	Cancelled
83-10	28 Nov 83	Superseded by ETL 86-1
84-1	18 Jan 84	Superseded by ETL 86-14
84-3	21 Mar 84	Cancelled
84-4	10 Apr 84	Superseded by ETL 86-7, 86-15, 87-5
84-5	7 May 84	Superseded by ETL 84-8, 86-11, 86-18, 88-6
84-6	Not Issued	Cancelled/Not Used
84-8	19 Jun 84	Superseded by ETL 86-11
84-9	5 Jul 84	Superseded by ETL 88-7
88-5	2 Aug 88	Superseded by ETL 91-6
86-1	3 Feb 86	Superseded by ETL 87-7
86-3	21 Feb 86	Superseded by ETL 86-4
86-6	3 Jun 86	Superseded by ETL 86-11, 86-18, 88-6
86-7	3 Jun 86	Superseded by ETL 86-15
86-11	3 Jul 86	Superseded by ETL 88-6
86-12	3 Jul 86	Superseded by ETL 90-2
86-13	18 Aug 86	Superseded by ETL 86-14
86-15	13 Nov 86	Superseded by ETL 87-5
86-17	17 Dec 86	Superseded by ETL 89-6
86-18	18 Dec 86	Superseded by ETL 88-6
87-3	12 Mar 87	Superseded by ETL 87-6, ETL 88-5
87-6	21 Aug 87	Superseded by ETL-88-5
87-7	14 Oct 87	Superseded by ETL 89-1
87-8	19 Oct 87	Superseded by ETL 90-1
88-1	5 Jan 88	Superseded by ETL 89-2
88-7	24 Aug 88	Superseded by ETL 90-3, ETL 91-2
88-8	4 Oct 88	Superseded by ETL 91-7
89-1	6 Feb 89	Superseded by ETL 90-4
89-5		Issued as ETL 90-7
91-8	24 Sep 91	Cancelled



# DISTRIBUTION LIST

## AIR FORCE

HQ AFMC/CEC 4225 Logistics Ave Wright-Patterson AFB OH 45433-5006	(3)	HQ USAFA/CEE 8120 Edgerton Dr, Suite 40 USAF Academy CO 80840-2400	(1)
HQ AFRES/CEO 155 2nd Street Robins AFB GA 31098-1635	(2)	1100 CES/CEM 1 McChord Street, Suite 208 Bolling AFB DC 20332-5109	(2)
HQ AETC/CEM Bldg 661, 73 Main Circle Randolph AFB TX 78150-4549	(3)	AFIT/DEE 2950 P Street Wright-Patterson AFB OH 45433-7765	(1)
HQ PACAF/CEC 25 E Street, Suite D-302 Hickam AFB HI 96853-5412	(3)	HQ ACC/CEM 129 Andrews Street, Suite 346 Langley AFB VA 23665-2769	(3)
HQ USAFE/CEO Unit 3050, Box 10 APO AE 09094-5001	(3)	HQ AFSOC/DE Bldg T-206, 301 Cody Ave Hurlburt Field FL 32544-5273	(1)
CETSO/ESOF 11817 Canon Boulevard, Suite 500 Crestar Bank Building Newport News VA 23606-2558	(1)	HQ USAF/CEC 1260 Air Force Pentagon Washington DC 20330-1260	(1)
HQ AMC/CES 507 A Street Scott AFB IL 62225-5022	(3)	ANGRC/CEO Bldg 3500, Mail Stop 18 Andrews AFB MD 20331-6008	(2)
HQ AFSPACECOM/CEO 150 Vandenberg Street, Suite 1105 Peterson AFB CO 80914-4150	(3)	AFCEE/CM/DG 8106 Chennault Road Brooks AFB TX 78235-5318	(2)
SSC/SBEE 201 East Moore Drive (Gunter Annex) Maxwell AFB FL 36114-3005	(1)	7 CG/XPGF 6345 Air Force Pentagon Washington DC 20330-1600	(1)
NGB/CEP Room 2D369, The Pentagon Andrews AFB MD 20310-2500	(1)	HQ AFOTEC/DE 8500 Gibson Boulevard SE Kirtland AFB NM 87117-5558	(1)
HQ AFIC/LEE Bldg 2000, Room 643 San Antonio TX 78243-5000	(1)	HQ AFMWSRA/MWXF Randolph AFB TX 78150-6001	(1)
HQ AFCC/CEM 203 W Losey Street, Rm 1020 Scott AFB IL 62225-5219	(2)	HQ AF Safety Agency/SEGS Norton AFB CA 92409-7001	(1)
		HQ AFOMS/SGS Brooks AFB TX 78235-5000	(1)
		HQ AF Inspection Agency/IGSE Norton AFB CA 92409-7001	(1)

## DISTRIBUTION LIST (Cont)

### ARMY

US Army Corps of Engineers (1)	Chief of Engineers (2)
Sacramento District	Department of the Army
AF Project Management	Attn: CEMP-EA
1325 "J" Street	20 Massachusetts Ave
Sacramento CA 95814-2922	Washington DC 20314-1000

### NAVY

Navy Facilities Engrg Command (1)	Naval Facilities Engrg Command (1)
Northern Division Code 04AB	Chesapeake Division Code 406C
10 Industrial Highway Mail Stop 82	Washington Navy Yard, Bldg 212
Lester PA 19113-2090	Washington DC 20374-2121
Naval Facilities Engrg Command (1)	Naval Facilities Engrg Command (1)
Atlantic Division Code 04A4	Southern Division Code 04A3
Norfolk VA 23511-6287	PO Box 190010
Naval Facilities Engrg Command (1)	North Charleston SC 29419-9010
Western Division Code 467.1	Naval Facilities Engrg Command (1)
PO Box 727	Pacific Division Code 406A
San Bruno CA 94066-0720	Pearl Harbor HI 96860-7300
Naval Facilities Engrg Command (1)	
Southwest Division Code 0406	
1200 Pacific Highway	
San Diego CA 92132-5190	

### DEPARTMENT OF DEFENSE

Defense Medical Facilities Off (1)	DTIC (1)
Skyline Place #6, Suite 817	ATTN: DTIC-FDA
5109 Leesburg Pike	Alexandria VA 22304-6145
Falls Church VA 22041	
AAFES/ATTN: CFE (1)	Defense Commissary Service (1)
PO BOX 660320	Director of Facilities
Dallas TX 75266-0320	Bldg 8400
	Lackland AFB TX 78236-5000

### SPECIAL INTEREST ORGANIZATIONS

IHS (A.A. Desimone) (1)	Construction Criteria Database (1)
1990 M Street NW, Suite 400	National Institute of Bldg Sciences
Washington DC 20336	1201 L Street NW, Suite 400
	Washington DC 20005